

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1110277

**Product:** Electroinstallation pliable conduit LPE - x (series EN) and accessories

**Type:** 2316E/LPE-1 to 2363/LPE-1  
2316E/LPE-2 to 2363/LPE-2  
(type designation see enclosure)

**Rating:** -25 °C to +90 °C, material spreading flame, for installation of up to 1000 V AC

**Ordering firm:** KOPOS KOLÍN a.s.  
Havlíčkova 432, 280 94 Kolín IV, Czech Republic

**Manufacturer:** KOPOS KOLÍN a.s.  
Havlíčkova 432, 280 94 Kolín IV, Czech Republic

**Trade mark:**


The test results are stated in the test-report No.: 100678-01/01 of: 17.03.2011

A sample of the product was found to be in conformity with:  
ČSN EN 61386-1:04, ČSN EN 61386-22:04

The validity of the certificate is limited to: 31.3.2014

28.3.2011

Prague

  
Miroslav Sedláček  
Head of Certification Body



Stamp



\* C E R / 1 1 1 0 2 7 7 \*

100678-01

**Elektroinstalační trubky ohebné LPE-x (řada EN) a příslušenství**  
**Electroinstallation pliable conduit LPE-x (series EN) and accessories.**

**(-25°C až +90°C) / (-25°C to +90°C)**

**Elektroinstalační trubky typ: / Electroinstallation pliable type:**

320 N	125 N
2316 E/ LPE-1	2316 E/ LPE-2
2320 / LPE-1	2320 / LPE-2
2325 / LPE-1	2325 / LPE-2
2332 / LPE-1	2332 / LPE-2
2340 / LPE-1	2340 / LPE-2
2350 / LPE-1	2350 / LPE-2
2363 / LPE-1	2363 / LPE-2

<b>spojky / couplers:</b>	<b>0216E/1 – 0263/1</b>
<b>ucpávky do trubek / pliable plug</b>	<b>1716E T - 1763 T</b>
<b>ucpávky do spojek / joint plug</b>	<b>1716E S - 1763 S</b>
<b>přechodové spojky z dimenze 20 na 16</b> transition couplers from dimension 20 on 16	<b>0206E/1</b>
<b>přechodové spojky z dimenze 20 na 2x16</b> transition couplers from dimension 20 on 2x16	<b>0207E/1</b>
<b>protahovací drát / pull-out wire</b>	<b>D</b>

*Handwritten signature*

