

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE DESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1110994

Product: Pliable conduit LPFLEX for very low mechanical strength and accessories

Type: 2313, 2316, 2323, 2329, 2336, 2348, 2316E-2363

Rating: installation in do 1000 V, -5 °C to +60 °C, classification coding 1121

Ordering firm: KOPOS KOLÍN a.s.
Havlíčková 432, 280 94 Kolín IV, Czech Republic

Manufacturer: KOPOS KOLÍN a.s.
Havlíčková 432, 280 94 Kolín IV, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 104107-01/01 of: 10.11.2011

A sample of the product was found to be in conformity with:
ČSN EN 61386-1ed.2:09, ČSN EN 61386-22:04, (IEC 61386-1:2008, IEC 61386-22:2002), TP-KO-04/98

The validity of the certificate is limited to: 30.11.2014

15.11.2011

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



104107-01