

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1110886

**Product:** Pliable conduit MONOFLEX for low mechanical strength and accessories

**Type:** 1416E, 1420 -1463, 1413/1-1448/1

**Rating:** -5 °C to +60 °C, sort code 2221

**Ordering firm:** KOPOS KOLÍN a.s.  
Havlíčkova 432, 280 94 Kolín IV, Czech Republic

**Manufacturer:** KOPOS KOLÍN a.s.  
Havlíčkova 432, 280 94 Kolín IV, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 102966-01/01 of: 30.09.2011

**A sample of the product was found to be in conformity with:**  
ČSN EN 61386-1 ed.2:09, ČSN EN 61386-22:04, TP-KO-06/98

**The validity of the certificate is limited to:** 31.10.2014

5.10.2011

Prague

Miroslav Sedláček  
Head of Certification Body



Stamp



102966-01