

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1100341

**Product:** Doublecoated pipes, wiring pipes and trunkings

**Type:** KOPOFLEX, MONOFLEX HF, PVC, trunking PVC

**Rating:** -

**Ordering firm:** KOPOS KOLÍN a.s.  
Havlíčková 432, 280 94 Kolín IV, Czech Republic

**Manufacturer:** KOPOS KOLÍN a.s.  
Havlíčková 432, 280 94 Kolín IV, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 000893-01/01 of: 04.05.2010

A sample of the product was found to be in conformity with:

ČSN EN 61386-1:09 ed.2 čl. 10.2,  
ČSN EN 61386-22::04 čl.10.2,  
ČSN EN 50085-1:06 ed.2 čl.10.3.2,  
ČSN EN 50086-1:96+Z1:04, ČSN EN 50086-2-4:96+A1:01

**Next information:** Tests for resistance to compression and impact before and after accelerated ageing with UV and IR light

The validity of the certificate is limited to: 31.5.2013

13.5.2010

Prague

Miroslav Sedláček  
Certification and Inspection Manager



Stamp



000893-01