

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 2110074

Ordering firm: KOPOS KOLÍN a.s.
Havlíčková 432, Kolín IV, 280 02 Kolín, Czech Republic

Manufacturer/Licence holder: KOPOS KOLÍN a.s.
Havlíčková 432, Kolín IV, 280 02 Kolín, Czech Republic

Production site: KOPOS KOLÍN a.s.
Havlíčková 432, Kolín IV, 280 02 Kolín, Czech Republic

Name of product: Cable tray to protect a line

Trade name:

Type of product: KOPOKAN 1, SPOJKA Z1, SPOJKA K1

Rating: instalation up to 1000 V, 750 N, IP 30

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „ESČ Mark” certification scheme is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESČ Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 103896-01/01 of: 09.12.2011

A sample of the product was tested and found to be in conformity with:
ČSN EN 61386-1 ed. 2:09, ČSN EN 61386-24:11, TP-KO-01/11

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 No. 104674-01 of: 08.11.2011
- the Agreement on the use of the ESČ Mark No. 103896 concluded between the ordering firm and the Electrotechnical Testing Institute

Other data:

18.04.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



* C E R / 2 1 1 0 0 7 4 *

103896-01